

OFFICE OF THE SULLIVAN COUNTY PURCHASING AGENT
3411 HIGHWAY 126 – SUITE 201
BLOUNTVILLE, TN 37617-0569

KRISTINIA DAVIS
PURCHASING AGENT

PHONE 423/323-6400

FAX 423/323-7249

Kris.davis@sullivancountytn.gov

ADDENDUM-1

RFP: 1482018(KD)

Re:

**LED Lighting Replacement
at Emmett Elementary School**

This addendum is issued to follow up questions/corrections that has been submitted as of 1/2/18 regarding the LED Lighting Replacement at Emmett Elementary School

- 1. Correction** – Per TVA project must be completed by **July 1, 2018.**
- 2. Question:** On the 2x4 and 2x2 grid troffer lighting fixtures can 4000k be proposed instead of 5000k? **Answer:** No classes will have 5000k
- 3. Question:** On the zone controls do we need dimming as well? **Answer:** Yes we do need dimming.

END OF ADDENDUM #1