

City of Havelock
Walk-in Freezer for Senior Center

Addendum 1

May 18, 2020

Questions Received

1. Can the utilities be ran above ground or will they need to go underground?

Utilities are to be run underground.

2. If the electrical has to go underground will we cut and repair the asphalt?

Any associated asphalt repair is the responsibility of the Contractor.

3. Is the electrical panel a 3 phase panel?

A single and a three phase panel is available on site.