



## **ADDENDUM #1**

**RALPH SCHUMACHER SOCCER PARK  
LED LIGHTING PROJECT  
(18507 US HWY. 98)  
Requisition No. PR-071024  
June 28, 2024**

Addendum #1 is being issued to address the following:

1. Primary lines and transformer: Riviera Utilities will take care of the installation of all primary (high voltage) underground lines and the installation of the transformer. The contractor will be required to frame up and pour a concrete pad for the transformer, based on our specifications.
2. Secondary lines (low voltage): From reading the full load amps of all circuits, it appears that the service size will be 400 amps. With a 400 amp service, Riviera will install the secondary wires to the meter service. The contractor will need to provide the framing for the meter service, (such as an H-frame), along with mounting the meter base that Riviera will provide. If the electrical contractor determines that a 600 amp service is needed, (due to other power needs not covered under the specification sheets provided), then the contractor will be responsible for installing the secondary wires from their disconnect panel to the Rivera transformer.
3. File named "Foley Soccer Fields 3 and 4 Control Summary" which is a document title "System Requirements: Control System Summary" was not published on the website with the initial bid documents and is being included for more information.

Please include this Addendum with your bid and acknowledge receipt of Addendum #1 on page 3 of the original bid packet.

Rachel Keith  
Project Manager  
City of Foley, Alabama