



**ARLINGTON COUNTY, VIRGINIA
OFFICE OF THE PURCHASING AGENT**

INVITATION TO BID NO. 24-DES-ITBPW-407

ADDENDUM NO. 3

Arlington County Invitation to Bid No. 24-DES-ITBPW-407 for Equipment Bureau Roof Replacement is amended as follows:

PROVIDE AGENDA AND ATTENDEE LISTS FROM MANDATORY PRE-BID/SITE VISITS, INCLUDED AS SEPARATE ATTACHMENTS.

RESPOND TO QUESTIONS RECEIVED BY THE QUESTIONS DEADLINE:

QUESTION 1: Please verify that NRCA membership certification will suffice for the bid submission on bid package Page 8 Item 19.

ANSWER 1: Membership certification does not suffice. Bidders must be certified by National Roofing Contractors Association (NRCA) **and** by the manufacturer of the system proposed. These certifications must be provided with the bid submission.

QUESTION 2: Do we have to have a business license in Arlington to be able to bid or is this something we must get after being awarded the job?

ANSWER 2: An Arlington County Business License is not required for bid submission. However, the successful Bidder must comply with the provisions of Chapter 11 ("Licenses") of the Arlington County Code, if applicable.

QUESTION 3: what is the existing roof installation thickness and type of existing roof decking for all three section? (corecuts)

ANSWER 3: The existing roof is 4"- 4.5" in thickness on a metal deck over steel joists.

The balance of the solicitation remains unchanged.

Arlington County, Virginia

Kaylin Schreiber
Procurement Officer

RETURN THIS PAGE, FULLY COMPLETED AND SIGNED, WITH YOUR BID:

BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM NUMBER 3.

FIRM NAME: _____

**AUTHORIZED
SIGNATURE:** _____ **DATE:** _____