



**Invitation for Bid #16-052
Brian Court Stream Stabilization – Phase 2**

ADDENDUM 1

Addendum issued August 31, 2016

A non-mandatory pre-bid meeting was held August 30, 2016 at 2:00pm at Wentzville City Hall.

The following clarifications are hereby incorporated into the Invitation for Bids:

1. Sod shall consist of materials which conform to the City of Wentzville Standard Specifications, Section 803. Sod shall not be placed during a drought, nor from June 1 to Sept. 1 unless authorized by the City, and shall not be placed on frozen ground. No dry or frozen sod shall be used.
2. Class A and Class C excavation are referenced in the City of Wentzville Standard Specifications and Construction Details Section 200.
3. Trees to be protected or removed are not marked onsite. The contractor shall mark trees to be removed for city approval prior to removals.
4. The City cannot recommend quarries to meet the gradations for the project. There are several quarries who have supplied similar size rock on other projects, including Magruder Limestone Co., LaFarge, and Central Stone Co.
5. Due to potential construction disturbance near the Thanksgiving and Christmas holidays, the Contractor shall make notification to all impacted properties after the pre-construction conference meeting. Notification shall advise them of construction schedules as well as impacts to their property and traffic/access due to mobilization and staging.

All other Terms and Conditions as applicable to this Invitation for Bid shall remain as stated.

This addendum forms a part of the contract documents and modifies the original bidding documents dated August 19, 2016. Contractor shall acknowledge receipt of this addendum in the space provided on the Bid Proposal Form (Exhibit A). Failure to do so may subject bidder to disqualification.

End of Addendum 1