

## **ADDENDUM NO. 1**

DATE: April 4, 2019

TO: All Bidders

FROM: Penny Owens, Assistant Purchasing Agent

SUBJECT: Addendum No. 1 – Palmetto Road Sidewalk Project

BIDS TO BE OPENED: April 10, 2019, at 11:00 a.m. (Eastern)

This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

### **Clarification of Contract Documents and Specifications:**

The following are responses to questions received from potential bidders:

#### **Questions**

1. Q: Have cores been taken on the existing road to determine the asphalt thickness?

A: Yes, there were previous cores taken and adjustments made for the overlays since. The asphalt is approximately 5.5 inches thick. The excavation of asphalt is included in Item No. 4.20, Common Excavation and shall be paid per cubic yard.

2. Q: Due to the amount of saw cutting involved for the new curb lines, should an item for saw cutting be added?

A: No, the cost for saw cutting shall be included in the cost for Item No. 4.20, Common Excavation.

**END OF ADDENDUM NO. 1**