



Terry McKee, IT & Procurement Director

901 N. Broadway • Knoxville, TN 37917-6699

865.403.1133 • Fax 865.594.8858

[purchasinginfo@kcdc.org](mailto:purchasinginfo@kcdc.org)

[www.kcdc.org](http://www.kcdc.org)

### Addendum

Solicitation Name	Alterations at Passport Properties C20003	Addendum Number	1	Date	08/05/2019
-------------------	---	-----------------	---	------	------------

This addendum answers questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in **bolded blue**, and the answers follow immediately below.

Q1	Does KCDC want flooring samples?
	<b>Yes.</b>
Q2	Has KCDC standardized on the specified locks?
	<b>Yes KCDC has standardized on Stanley's Landlord I-Core Locks.</b>
Q3	Is there HVAC duct work?
	<b>No it is all exterior.</b>
Q4	Is there any HVAC grill work required inside the apartments?
	<b>Yes KCDC wants a price for replacing the registers. See the revised pricing page following this page.</b>

### KCDC wishes to add the following information:

1. Units with a 3 ton furnace in the attic may need modifications to the ceiling in order to get the furnace in the attic. Only the old furnaces in these units are allowed to stay in the attic.



**REVISED Interior Alterations at the Passport Property C20003**  
**Solicitation Document A General Information and Cost**

Pursuant to and in compliance with the solicitation documents, the supplier signing Solicitation Document A, having thoroughly examined the work to be performed, agrees to perform the work for the following total bid amount for the above referenced project. The prices quoted cover all of the supplier's expenses including, but not limited to, overhead, profit, insurance, subcontractors, supplies and bonding.

**Complete all "blanks"-even if the amount is \$0.00**

Cost Information	
<b>Total Project Cost for Passport Property Renovations C20003</b>	<b>\$</b>

Alternates	
<b><u>Alternate No. 1: Vinyl Sheet Flooring only the bathroom and kitchens</u></b>	
1. Base Bid Item: Section 09 65 00 - Resilient Flooring and Drawing numbers 1/A2.1, 1/A2.2, 1/A2.3, 1/A2.4, 1/A2.5, 1/A2.7, 1/A2.8, 1/A2.9.	-\$
<b><u>Alternate No. 2: Using LVP in lieu of resilient sheet flooring</u></b>	
1. Base Bid Item: Section 09 65 00 - Resilient Flooring and Drawing numbers 1/A2.1, 1/A2.2, 1/A2.3, 1/A2.4, 1/A2.5, 1/A2.7, 1/A2.8, 1/A2.9.	+\$

Unit Prices		
Description	Cost	Unit of Measure
Cutting doors (including the entire process of removing, cutting and re-installing)	\$	Each
Cost to replace a HVAC grill cover	\$	Each