

ADDENDUM NUMBER SEVEN

**23rd STREET PUMP STATION ELEVATOR UPGRADE
CONTRACT NO. W-19-025-201**

CITY OF CHATTANOOGA, TENNESSEE

The following changes shall be made to the Contract Documents, Specifications, and Drawings:

I. Contract Documents.

Q? Thank you again for allowing us the site survey yesterday morning. We are in the final stages of putting our quote together and one main point of concern we have is with page 212 of the bid document. I have attached the particular page with 3 line items highlighted. The current scope states we should retain the current governor, governor rope, & Governor rope shackles. All 3 items are original to the install in 1953 and we believe all 3 need replacing. The governor is a critical safety device that ensures the elevator can never fall down the hoistway. Newer elevators and new safety code requires an overspeed safety switch to be mounted with the governor to pass inspection and the current governor does not have the capabilities to include.

Is it possible to amend the bid to include replacing all three items? tkE feels this is a crucial safety item that must be updated and we intend to include it in our bid. We think the state will require this too to pass inspection.

- A.** Change from “Retain existing” to “Provide new” of the three items, Governor, Governor rope, & Governor rope shackles under Machine Room in the Detailed Specifications. This will be rolled into the Lump Sum portion of the existing Bid Schedule.

January 23, 2020

/s/Justin Holland, Administrator
City of Chattanooga
Department of Public Works