



City of Myrtle Beach

SOUTH CAROLINA

PURCHASING AND
MATERIALS MANAGEMENT

(843) 918-2170
FAX: (843) 918-2182

ADDENDUM 001

Art Museum Roof Replacement

21-B0002

July 21, 2020

The following questions have been asked and answered.

Question:

1. Would the City of Myrtle Beach be interested in a TPO roof system vs EPDM roof system?

Answer:

Yes. Please DELETE EPDM from specifications and ADD TPO roof system. TPO roof system spec: J. Mansfield or equal and must follow manufactures specifications and guidelines.


Question:

2. The cutting back of the Five Dormers and two existing Chimneys, whose responsibility?

Answer:

Grand Strand Builders will be responsible for cutting back the five dormers and two chimneys, plus the repair of the existing concrete board. The Roof Contractor is responsible all flashing requirements.

Thank you for your interest in this project,


Ruth Burleson Garigen/Buyer
City of Myrtle Beach