

**ADDENDUM FOUR  
AVONDALE YOUTH AND FAMILY DEVELOPMENT CENTER  
BUILDING ABATEMENT AND DEMOLITION  
CONTRACT NO. Y-15-008-202  
CITY OF CHATTANOOGA, TENNESSEE**

The following changes shall be made to the Contract Documents, Specifications, and Drawings:

**I. Bid Date**

**A. The bid date is being extended to Thursday, August 15th. The time and place of the bid opening is unchanged.**

**II. Questions and Responses**

**Q1. Will it be possible for the concrete and block to be recycled?**

A1. The concrete and masonry that are part of the building must be disposed of at a landfill that is permitted for Construction and Demolition waste (C&D)

**Q2. At the new areas where we demo parking lots, tennis courts, and buildings, can the grade of the ground be left at the elevation after the demo is complete, or do we have to fill the void with new fill dirt to get it back to elevations that match the surrounding undisturbed dirt?**

A2. Areas disturbed shall be restored to pre-demolition grades.

**Q3. On the drawing marked D-001 and in regards to the demolition area marked in yellow, will this be the only area required by the demolition contractor to install the erosion control?**

A3. The demolition contractor will be required to install erosion control measures in accordance with the SWPPP and the drawings in the Plans to prevent migration of sediment and debris and to control erosion in the area of the demolition contractor's work. Erosion control measures will be installed at locations and as needed to achieve the necessary control of erosion.

**Q4. Also, the fence on Dodson Ave above the picnic area, does it come down?**

A4. The remnant of fence on Dodson Avenue does need to be removed south to the line of trees.

August 6, 2019

---

/s/ Justin C. Holland, Administrator  
City of Chattanooga  
Department of Public Works