FIRE PROTECTION GENERAL NOTES

1. REFER TO CIVIL DRAWINGS FOR LOCATIONS OF FIRE HYDRANTS AND SITE FIRE PROTECTION DETAILS.
2. PROVIDE COMPLETE WET PIPE SPRINKLER PROTECTION FOR ALL AREAS OF THE BUILDING IN ACCORDANCE WITH NFPA 13 AND LOCAL AUTHORITY HAVING JURISDICTION.
3. UNLESS OTHERWISE NOTED, PROTECT AREAS OF THE BUILDING IN ACCORDANCE WITH NFPA 13 REQUIREMENTS FOR LIGHT HAZARD OCCUPANCIES.
4. PROTECT STORAGE ROOMS, STAGE AREA, MECHANICAL ROOMS, POOL EQUIPMENT ROOM, FOOD BANK AND ELECTRICAL ROOMS, AND IN ACCORDANCE WITH NFPA 13 REQUIREMENTS FOR ORDINARY HAZARD GROUP ONE OCCUPANCIES.
5. PROVIDE SPRINKLER HEADS FOR UNDERSIDE OF TRACK IN OPEN AREAS ON ZONE 2.

FIRE PROTECTION ZONE 1

FIRE PROTECTION ZONE 2

PROTECT IN ACCORDANCE WITH ELEVATOR INSPECTOR REQUIREMENTS

ZONE 1 A/S LINE UP SEE DWG. P0.22 FOR CONTINUATION

ROUTE LINE TIGHT TO UNDERSIDE OF RUNNING TRACK

ROUTE LINES TIGHT TO UNDERSIDE OF RUNNING TRACK

FIRE DEPT. CONNECTION - 8" FIRE LINE, SEE SITE PLAN FOR CONTINUATION

FIRE LINE DOUBLE DETECTOR CHECK ASSEMBLY

ZONE 3 A/S LINE UP SEE DWG. P0.22 FOR CONTINUATION

ZONE 3 ALARM CHECK VALVE ASSEMBLY

ZONE 1 ALARM CHECK VALVE ASSEMBLY

ZONE 2 ALARM CHECK VALVE ASSEMBLY

ZONE 2 WALL POST INDICATOR VALVE

ZONE 1 WALL POST INDICATOR VALVE

ZONE 3 WALL POST INDICATOR VALVE

Talking Lot (2) Cam's ??? 49-50

= Indoor Camera

= Outdoor Camera

Cam's (23) DOWN STAIRS

KEY PLAN N.T.S.

OVERALL FIRST FLOOR PLAN – FIRE PROTECTION

0 4' 8' 16' 24'

BARGE WAGGONER SUMNER & CANNON, INC.

BWSC

162 THIRD AVENUE NORTH, NASHVILLE, TENNESSEE 37201
PHONE: (615) 254-1500 FAX: (615) 255-6572
E-MAIL: NASHVILLE@BARGEWAGGONER.COM

ENGINEERS ARCHITECTS PLANNERS LANDSCAPE ARCHITECTS SURVEYORS

FIRST FLOOR FIRE PROTECTION PLAN

A NEW RECREATIONAL CENTER FOR THE PATTERSON PARK COMMUNITY

MURFREESBORO, RUTHERFORD COUNTY, TENNESSEE

REV.	DESCRIPTION	DATE	CHK.
	ORIGINAL ISSUE	10-18-99	TH

APPROVED FOR DISTRIBUTION
QUALITY ASSURANCE AUTHORITY

DR. DHK

P0.21

FILE NO. 24508-04

B.O.

BWSC$PLOT$TIME$$$
BWSC$FILE$NAME$$$