



ADDENDUM NO. II

DATE: June 24, 2021
TO: All Potential Proposers
FROM: James McKeehan, Assistant Purchasing Agent, City of Knoxville
SUBJECT: Addendum No. II to RFP - Holiday Ice Rink

This addendum is being published to provide clarification regarding the above referenced RFP. This addendum becomes a part of the contract documents and modifies the original specifications as follows:

Items for Clarification:

1. In the past have the headers to the rink been a side feed or end feed? How much room is available for an end feed past the back of the dasher boards?

In the past the headers have been side feed. There is approximately 10 feet from the back of the dasher boards to the chiller.

END OF ADDENDUM NO. II