



Terry McKee, IT & Procurement Director

901 N. Broadway • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 purchasinginfo@kcdc.org
 www.kcdc.org

Addendum

Solicitation Name	Renovations at Western Heights C19010	Addendum Number	2	Date	11-01-2018
--------------------------	---------------------------------------	------------------------	---	-------------	------------

This addendum answers questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in **bolded blue**, and the answers follow immediately below.

Q1	Conflict resolution. Drawing Page A301 ELEVATION NOTES: ITEM 2; 2.4 denotes to "Prime and Paint all Brick, Pre-Cast Concrete..." however the SPECIFICATIONS SECTION 09 9113 EXTERIOR PAINTING; PART 1 GENERAL; 1.01 D "Do not paint or Finish the following items: ...NOTE #6. Brick". Do we include painting the outside of the buildings?
Q2	Drawing Page E102; REFERENCE NOTES FOR TYPE D BUILDING; #5 "...See note # 9." Note number # 9 is not included. What is "Note # 9" for Reference Notes on Type D buildings?
	<p>1. Specification Section 09 9113 Exterior Painting is for building elements other than brick and pre-cast window sills. Section 09 9600 High-Performance Coatings is specifically for brick masonry and pre-cast concrete sills.</p> <p>a. Section 1.01.C. – Change #3 to “Window Trim.”, thereby removing the “and cast sills”.</p> <p>2. E102, Building B – Note #5 should reference Note #8.</p> <p>3. E102, Building D – Note #5 should reference Note #8 and Note #7 and #8 should reference note #6.</p>
Q3	Will KCDC arrange a second tour of the site?
	KCDC will offer a second tour on Friday November 2, 2018 at 10:30 a.m.

