

Addendum 4

City of Canton, Ohio
Purchasing Department
218 Cleveland Ave. SW, 4th floor
Canton, Ohio 44702

STA 9th St SW Bridge Replacement Project - GP 1298

Item/Project

Engineering Department

Responsible Department

2:00 PM, 3/2/2023

Proposals Due By

Proposal Submitted By:

Company Name

Street Address

City

State

Zip

Contact Person

Phone No.

Email Address

Question 1:

Our insurance company has indicated that there is not a limit listed in the documents for the Professional Liability. Please clarify.

Answer 1:

The limits for the liability are listed under the Proposal Note 100 - LPA Construction and Materials Specifications section of the Invitation to Bid. Item 107.12: Responsibility for Damage Claims and Liability Insurance, subsection B lists the limits. Additionally, a form will be submitted to the apparent low bidder with specific liability insurance information.

Question 2:

Likewise, there is no limit listed for the Pollution Liability. Please clarify

Answer 2:

This is an ODOT funded project and ODOT does not require a minimum limit for pollution liability.

Question 3:

Plan sheet 37/70 of the plans under the heading pile driving states the minimum energy of the hammer used to install the piles shall be 72,000 foot-pounds. This is twice the energy normally required to install 12" pile in this area. Can the design engineer provide additional information on the plan requirement for using a hammer with this much energy?

Answer 3:

It looks like that was a typo. The minimum rated energy of the hammer used to install the piles shall be 6,000 foot-pounds.

Question 4:

On sheet 50/70, if the 5 additional intermediate cross frames in bay one opposite the sanitary supports are included in ref 80 structural steel members, level 3 by the pound item or in ref 93 structures: sanitary support/anchorage lump sum item.

Answer 4:

The additional five (5) intermediate cross frames in bay one opposite the sanitary supports shall be included with Item Special - Structures: Sanitary Support/Anchorage (Lump Sum item, REF 93).