

Addendum Revision

Solicitation Name	HVAC Replacement for Eastport 2 C25001	Addendum Number	1	Date	07/12/24
--------------------------	--	------------------------	---	-------------	----------

This addendum answers questions raised about this solicitation. Questions are generally verbatim as received. To aid in readability, the questions are in black, and the answers are in **bolded blue** following immediately below.

Q1	<p>Which style unit would be more economical and desirable by KCDC:</p> <ol style="list-style-type: none"> 1. An HVAC system with duct for the corridors 2. Replace Mini split units similar to what is existing?
	<p>KCDC is looking for bidders to recommend one over the other by indicating which they are recommending and why. Indicate this in your bid document.</p>
Q2	<p>If we were given verbal answers during our site visit, can we rely on those answers?</p>
	<p>Any staff answers given, must be followed up by written questions submitted through KCDC's bid portal. The written answers supplied to those submitted questions can be relied on. However, KCDC does provide these officials answers:</p> <ol style="list-style-type: none"> 1. The thickness of the wall with brick is approximately 12 inches. 2. The existing HVAC breaker is 20 amp and may need changed to accommodate the new PTAC unit. 3. The existing Inside Air unit in the ceiling can be left (no need to demo). 4. The Existing Condenser at the exterior will need to be demolished and removed to make room for the new condensers needed for the corridor units. 5. The Plug location for the PTAC will be in the wall, adjacent to the unit