



PURCHASING AND
MATERIALS MANAGEMENT

City of Myrtle Beach
SOUTH CAROLINA

(843) 918-2170
FAX: (843) 918-2182

ADDENDUM 001

BID# 17-B0049

POLE LIGHTS

The following questions have been received and answered for Bid# 17-B0049, Pole Lights.

1. What is the height of the Pole?
12 feet
2. How does the Pole anchor?
Anchor Bolts to the existing concrete

The bid opening will remain the same, 2:00PM Tuesday March 28, 2017

Thank you,


Ruth Burleson