OFFICE OF THE SULLIVAN COUNTY PURCHASING AGENT 3411 HIGHWAY 126 – SUITE 201 BLOUNTVILLE, TN 37617-0569

KRISTINIA DAVIS PURCHASING AGENT

PHONE 423/323-6400 FAX 423/323-7249 Kris.davis@sullivancountytn.gov

ADDENDUM-1

TO

RFP EBCE2016(KD) RE-ROOFING BLUFF CITY ELEMENTARY KITCHEN/DINING AREA Re: CLARIFICATIONS ON SPECIFICATION SHEET

- 1. ITEM #1 Requiring only wet and or damaged insulation and wood decking shall be replaced. Quote cost per Sq. Ft. to replace such material.
- 2. ITEM #2 Contractor to replace ALL wood around the perimeter with treated wood, either 2x4 or 2x6 plate.
- **3.** ITEM #3 EPDM will not be accepted as it cannot be heat welded.
- **4.** ITEM #6 Off white color will be accepted.
- 5. Testing is being conducted on roof for asbestos and results will be back by 4/18/16, as to what material is within the roof system. Update will be sent at that time.

PLEASE ACKNOWLDGE RECEIPT OF THIS ADDENDUM TO EMAIL ADDRESS: kris.davis@sullivancountytn.gov

RE-ROOFING/RFP# EBCE2016(KD)

PRICE SHEET

Specify Roof System Manufacturer:_____

Warranty:_____

1.Bluff City Elementary Kitchen & Dining Area Re-roofing **BID PRICE \$_____**

a. Quote unit price for removal and replacement of deteriorated existing wood.

\$_____per sq. ft.

b. Quote unit price for removal and replacement of metal.

\$_____per sq. ft.