



Terry McKee, IT & Procurement Director

901 N. Broadway • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 purchasinginfo@kcdc.org
 www.kcdc.org

Addendum

Solicitation Name	Fire Extinguisher Services Q1930	Addendum Number	1	Date	03-21-19
--------------------------	----------------------------------	------------------------	---	-------------	----------

This addendum answers questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in **bolded blue**, and the answers follow immediately below.

Q1	How many extinguishers are inside the dwellings?
	<ul style="list-style-type: none"> • 99% of the fire extinguishers are in our 3,500 apartments. 99% of those are 2.5 pounds. • There are also 2.5 pounders in our vehicles. • The other fire extinguishers are in common areas and a few office areas. Mostly these are 5 pounders but some are 10 pounders.
Q2	Can Badger Fire extinguishers be substituted?
	Yes as long as they are equal to the current brand and if they will fit the existing brackets. If they do not fit the existing brackets, then the supplier will furnish and install new brackets at no additional cost.
Q3	How are the inspections usually carried out? Are they brought all to one location or do we enter every apartment?
	The vendor will enter every apartment.
Q4	Will KCDC extend the bid due date to allow us time to prepare better bids?
	Yes. Responses are now due by 11:00 a.m. on 03-26-19.

