

Tom Green County



113 W. Beauregard Ave.
San Angelo, Texas 76903
325-659-6500/Fax 325-659-5441

RFP 24-001

Goodfellow Air Force Base DEAAG Fire Station Addition/Alteration

10/23/2023

ADDENDUM NO 1:

Notice to Vendors: Clarification Request

- 1. We cannot find detail 5/S501. This detail is called out several times on the plans, but when you go to sheet S501 we do not see it. Can you get us this detail?:**

GAFB CE Response: Please find the attached updated plans "RFP 24-001 Project Drawings New". Drawing S101, detail symbols "5/S501" have been corrected to indicate Detail 7 "Thickened Slab Edge Dtl" and Detail 8 "Packaged Unit Pad Dtl" respectively. These changes should not cause any changes to the original project specifications.

- 2. I need clarification for the LVP to be used as an accent wall in the common area. There is not enough information in the finish schedule or spec book to determine which product they are wanting.:**

GAFB CE Response: Refer to Page A801 on the bottom of the finish legend as well as the attached spec sheet "RFP 24-001 LVP Spec Sheet". If item is no longer available, substitutions can be made if approved via submittals, as long as they meet similar specifications for warranty, thickness, wear layer, backing, color, etc. similar to the Kolay that is specified.

Please include this signed addendum with your response.

Sincerely,



Dustin Klein
Procurement Supervisor

Company

Date

Signature

Please Print Name and Title