

Summer Resurfacing Questions Answered

1. Items 14 and 23 for "Borrow Excavation" have been provided with a square yard quantity. Should the contractor assume that the depth/thickness of this borrow excavation should match the "Unclassified Excavation" items at 18" deep? **Unclassified Excavation and Borrow Excavation items have been converted to Cubic Yards to reflect 18" in depth. Borrow Excavation quantities account for compaction. These quantities are an allowance to excavate enough to find suitable material to be able to add Borrow Excavation material. Hopefully it will not be necessary to use all these quantities.**
2. The specs reference (item 10 on page 7) that permanent raised pavement markers (RPMs) should be replaced on roads with existing raised pavements markers. However, the bid items only include the items for lanes lines and stop bars. If the town does in fact require RPMs to be installed, how will these be paid for? **RPMs were added as a bid item Number 177 on page 30. Note; RPMs only for state roads.**
3. Will the town provide adjustments for Fuel per SCDOT standards, as you are similarly handling Liquid Asphalt adjustments? **Yes**
4. Will the job be paid for by actual quantities performed, or will this be a lump sum contract? **This is a unit price contract, so paid for quantities performed.**
5. Item 23 in the General Provisions directs the contractor to provide a sales tax line item broken out separately from the bid items. There does not appear to be anywhere for this information to be listed in the bid pricing documents. Please confirm if this will be required for this bid. **This provision is not required.**