



OFFICE OF PROCUREMENT SERVICES
 335 FOUR MILE ROAD
 CONWAY, SC 29526-6005

AMENDMENT/ADDENDUM No. 3

Posting Date: Friday, April 3, 2020

Solicitation Number: 1920-54VS

Description: Tennis Court Improvement Program – Phase I

ADDENDA: Addenda shall be issued prior to the bid opening date and time for the purposes of modifying or interpreting the Contract Documents through additions, deletions, clarifications or corrections. No addendum shall be issued later than four (4) days prior to the bid opening date except to a) withdraw the Invitation for Bids, or b) to postpone the bid opening date and time. When an addendum is issued for the purposes of postponing the bid opening date and time, the addendum shall establish the new bid opening date and time no earlier than five (5) days after the addendum issue date. Addenda shall be posted on the on-line bidding source(s) stated in the Invitation for Bids. A Bidder shall acknowledge receipt of all addenda issued by identifying the addendum number and the date of issuance with the Bidder's initials in the spaces provided on the Official Bid Form or the bid shall be found non-responsive in accordance with the District's Procurement Code. If this solicitation is amended, then all terms and conditions which are not modified remain unchanged.

INTERPRETATIONS AND CLARIFICATIONS: Requests for additional information or questions regarding error, omission or clarification of any portion of the Bid Documents or the Contract Documents or any addendum, shall be submitted in writing to the District Bid Contact Person stated in the Invitation for Bids by e-mail or facsimile no later than five (5) days prior to the bid opening date and time unless an earlier date is stated on the Invitation for Bids or as may be amended. Any interpretations, corrections, or changes to the Bid Documents or the Contract Documents made in any other manner than by a written addendum shall not be binding, and Bidders shall not rely upon them. Any information given a prospective Bidder concerning a solicitation will be furnished promptly to all other prospective bidders as an addendum to the solicitation, if that information is necessary for submitting offers of if the lack of it would be prejudicial to other prospective bidders. See clause entitled "Bidder Representations." We will not identify you in our answer to your question. The District seeks to permit maximum practicable competition. Bidders are urged to advise the Procurement Specialist – as soon as possible – regarding any aspect of this procurement, including any aspect of the solicitation that unnecessarily or inappropriately limits full and open competition.

BID OPENING DATE AND TIME REMAIN THE SAME

Question Number	Question	Answer
1.	I would like to request that an alternate backboard system be considered in lieu of the concrete block system and or as an add/deduct to the three high school tennis court projects. I would suggest the Bakko 10' tall x 40' wide "Professional Flat Series" tennis backboard. This Bakko backboard has sound dampening material in the back of the board and comes with a 5-year warranty. I would also suggest the fencing be strengthened behind this wall to include 3" schedule 40 weight vinyl coated 10' tall posts set every 4', and including schedule 40 mid-rail and bottom-rail in this 40' section for each court. I've found the concrete block walls are more expensive and harder to maintain over time.	Bidders will be allowed to price a Bakko 10' tall x 40' wide "Professional Flat Series" tennis backboard system as Bid Alternate #3. Pricing to include replacing the specified concrete block walls in the Base Bid with the 40 feet of 10' tall fencing with posts set at 4' O.C. and the Bakko 10' tall x 40' wide "Professional Flat Series" tennis backboard system.

2.	My question is for CHA to clarify the answer on the fence posts. The answer say that PERIMETER fence posts should be set prior to paving. How about the divider fence posts throughout the court?	Upon further review, CHA will accept the following three (3) options for installation of the perimeter fence posts at the tennis courts: • OPTION 1: Install the fence posts in concrete footings per the detail on Sheet C-601 prior to paving, then place asphalt by machine and hand, as necessary, around the posts such that the asphalt surface course is placed over the top of the concrete footings. • OPTION 2: Install sleeves for the fence posts in concrete footings prior to paving and set the top of the sleeve flush with the top of the asphalt surface course. Then place asphalt by machine and hand, as necessary, around the sleeves such that the asphalt surface course is placed over the top of the concrete footings. • OPTION 3: Install fence posts in concrete footings topped with a 4" deep by 18" wide continuous concrete mow strip as shown in <i>Figure 1 – Tennis Court Perimeter Edge – Bid Alt.</i> Costs for this option shall be reflected as an add or deduct from Base Bid and provided as Bid Alternate #2. • Interior fence posts shall be installed in sleeves in concrete footings prior to paving with the top of the sleeve set flush with the top of the asphalt surface course. Then place asphalt by machine and hand, as necessary, around the sleeves such that the asphalt surface course is placed over the top of the concrete footings.
3.	In Section 116833 1.2 Submittals: A structural drawing by an engineer for windscreens is called for. Is that need for this job?	Sealed structural drawings are not required for the windscreen. Section 116833 Outdoor Sports Equipment, Part 1.2 Submittals, Subpart C shall be deleted from the Contract Documents.
4.	Net posts are spec'd as green. The fence is black. They normally match. Also the windscreens are spec'd to be green. Again they normally match the fence.	Colors included in the specifications are placeholders. Final colors will be selected by the Owner for each project site from manufacturer's standard colors.
5.	Conway High School - Drawing C-100 Where the 10' fence makes a 90 degree turn at the hitting wall court, does that need to be a cut down to 3' fence? This is in the top corner of the triple. Carolina Forest High School - Drawing C-100 Is there a cut down where the 3' fence meets the 10' by the hitting wall court? I see the one where the fence makes a 90 degree turn by hitting wall.	All transitions from 10' high fence to 3' high fence at Carolina Forest High School and Conway High School should use the top rail transition detail shown in the Fence Elevation detail included as Detail 13 / Sheet C-601 in each drawing set. Detail does not apply to Green Sea Floyds High School.
6.	Is it okay to use all 3" posts for line posts and terminals posts on the 3' fence sections?	Minimum required fence post diameters for each height of fencing are shown in the table in Section 323113 Chain Link Fence and Gates, Part 2.1A.
7.	Changes to Contract Documents Specification Section 012300 ALTERNATES, Part 3.1 SCHEDULE OF ALTERNATES of the contract documents shall be amended as follows:	PART 3 – EXECUTION 3.1 SCHEDULE OF ALTERNATES B. Alternate No. 2: Alternate Tennis Court Perimeter – All Schools – Add 18"W x 4"D continuous concrete mow strip around the entire perimeter of tennis court limits as shown in <i>Figure 1 – Tennis Court Perimeter Edge – Bid Alt.</i> Bids for this alternate should reflect the reduced areas of asphalt paving and reduced areas of synthetic surfacing.

		<p>C. Alternate No. 3: Alternate Backboard System – All Schools - Replace the painted CMU hitting wall (Detail 2 / Sheet C-602) in the Base Bid with the following</p> <ul style="list-style-type: none">a. 40 feet of 10' HT. chain link fencing with posts set at 4' O.C.b. Bakko 10' tall x 40' wide "Professional Flat Series" tennis backboard system.
--	--	--

HORRY COUNTY SCHOOLS

By:

Robin B. Strickland, CPPB
Procurement Officer