



Jackson County Board of Commissioners

67 Athens Street
Jefferson, Georgia 30549
Phone: (706) 367-4174
Fax: (706) 708-2505
Email: kmorris@jacksoncountygov.com

Date: June 20, 2023

To: General Contractors

From: Kenneth Morris, Purchasing Manager

RE: Addendum 1 to Jackson County ITB 230008, Administration Building Generator, Jackson County

1. Addendum 1 is hereby issued to add clarifying specifications. The generator package shall include packaged engine generator system and associated components and accessories including alternator, engine & engine accessory equipment, generator set control system, generator set enclosure, auxiliary load bank, and three (3) automatic transfer switches (ATS); 1 200 amp ATS , 1 300 amp ATS, and 1 400 amp ATS for this invitation.
2. All other terms and conditions in ITB 230008 remain unchanged.
3. Any inquiries concerning Addendum 1 should be made to Kenneth Morris, Purchasing Manager, (706) 367-4174 or via email at kmorris@jacksoncountygov.com
4. Jackson County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.
5. Bidders must acknowledge receipt of addenda, by either signing and attaching this copy, or by writing "Acknowledge Addenda #1" at bottom of Bid Schedule.

AMENDMENT NO. ONE (1)

Date: June 20, 2023 Architect's Project No. A21-036A

PROJECT: CMAR Services for Jackson County Administration Building – Generator

Client: Jackson County Board of Commissioners

Contract for: Construction Manager at Risk

This Addendum forms a part of the Contract Documents and Construction Drawings and modifies the original Proposal Documents for the above referenced project.

CHANGES TO THE INVITATION TO BID:

A. CLARIFICATIONS

- C1. The generator package shall include packaged engine generator system and associated components and accessories including alternator, engine & engine accessory equipment, generator set control system, generator set enclosure, auxiliary load bank, and automatic transfer switches.

B. LIST OF ATTACHMENTS

None

PLEASE NOTE: Contractors must acknowledge receipt of this Addendum on the Bid Document form or by signing and returning a copy of the addenda with their bid package.

Amendment No. 1 Received by:

Contractor

Signature

Date

END OF AMENDMENT NO. ONE (1)