



**CITY OF DUBLIN
ADDENDUM #1
RFP #18-03-001
SOUTHERN PINES WATERPARK**

DATE: March 15, 2018
TO: All Interested Bidders
FROM: Kris Harden, Purchasing Director
SUBJECT: Addendum to Southern Pines Waterpark RFP #18-03-001

Please note the following changes to the RFP to read:

- Page 4, Section 2, line 2, identifies the "splash pad" as being protected, add "and the splash pad apron".
- Page 4, Section 3, paragraph A, last line, should be "Skimmers" instead of "Simmers".
- Page 5, Section 5, line 3: After "Floors shall be a minimum 6" thick with #4's at 12" o.c.e.w." add "Pool slabs shall be underlain with 6" of clean 57 stone (or finer) on undisturbed or compacted subgrade".
- Page 10, Tab B, Section G, line 2: Delete the word "audited".

Also, please note the addition of a 4' ornamental rail, Item L, on the drawing.

Should you have any questions, please call me at 478-277-5047 or e-mail hardenk@dlcga.com. Be sure to return all required forms that were sent with the original bid package.

I have read the above change and clarification to the original bid and will submit my bid accordingly.

Bidder: _____

Signature

Date

SOUTHERN PINES WATERPARK PLAN
 Dublin-Laurens County Recreation Authority

SCALE 1" = 50'
 February 5, 2018

0' 10' 25' 50'

LEGEND

- A Existing Entry Building
- B Existing Splashpad
- C New Slide Package
- D New Lazy River
- E New Shade Canopies
- F New Restroom Building
- G Remote Pump Shed
- H Relocated Water main*
- I Relocated Sewer*
- J New Fence
- K 4' ORNAMENTAL RAIL
- L * By Owner

