



OFFICE OF PROCUREMENT SERVICES  
335 FOUR MILE ROAD  
CONWAY, SC 29526-6005

**AMENDMENT/ADDENDUM No. 4**

**Posting Date:** Tuesday, October 11, 2022

**Solicitation Number:** 2223-02MJ

**Description:** Carolina Forest High (CFH)- HVAC Renovation Project

**ADDENDA:** Addenda shall be issued prior to the bid opening date and time for the purposes of modifying or interpreting the Contract Documents through additions, deletions, clarifications, or corrections. No addendum shall be issued later than four (4) days prior to the bid opening date except to a) withdraw the Invitation for Bids, or b) to postpone the bid opening date and time. When an addendum is issued for the purposes of postponing the bid opening date and time, the addendum shall establish the new bid opening date and time no earlier than five (5) days after the addendum issue date. Addenda shall be posted on the on-line bidding source(s) stated in the Invitation for Bids. A Bidder shall acknowledge receipt of all addenda issued by identifying the addendum number and the date of issuance with the Bidder's initials in the spaces provided on the Official Bid Form or the bid shall be found non-responsive in accordance with the District's Procurement Code. If this solicitation is amended, then all terms and conditions which are not modified remain unchanged.

**INTERPRETATIONS AND CLARIFICATIONS:** Requests for additional information or questions regarding error, omission or clarification of any portion of the Bid Documents or the Contract Documents or any addendum, shall be submitted in writing to the District Bid Contact Person stated in the Invitation for Bids by e-mail or facsimile no later than five (5) days prior to the bid opening date and time unless an earlier date is stated on the Invitation for Bids or as may be amended. Any interpretations, corrections, or changes to the Bid Documents or the Contract Documents made in any other manner than by a written addendum shall not be binding, and Bidders shall not rely upon them. Any information given a prospective Bidder concerning a solicitation will be furnished promptly to all other prospective bidders as an addendum to the solicitation, if that information is necessary for submitting offers or if the lack of it would be prejudicial to other prospective bidders. See clause entitled "Bidder Representations." We will not identify you in our answer to your question. The District seeks to permit maximum practicable competition. Bidders are urged to advise the Procurement Specialist – as soon as possible – regarding any aspect of this procurement, including any aspect of the solicitation that unnecessarily or inappropriately limits full and open competition.

---

The following revisions have been made and the new revised drawings are attached.

1. Sheets M1.0, M1.1, M1.2, M1.3, and M1.4. Change unit from downdraft with plenum curb to horizontal side discharge with 14" tall curb. Change unit location such that the long axis of the unit runs parallel to the building. Provide new concrete pad. Connect to existing supply and return ducts at building wall.
2. Sheet M2.0
  - a. Packaged Energy Recovery Unit Schedule. Updated to reflect change in unit from down draft to horizontal.
  - b. Detail 1. Updated to reflect horizontal discharge, platform curb and service platform.
  - c. Concrete pad shall be extended as required to include service platform.
3. Sheets E1.0, E1.1, E1.2, E1.3, E1.4 and E2.0. Drawings updated to reflect changes in makeup air unit electrical connection requirements.

**The bid opening date and time remain the same**