



## Jackson County Board of Commissioners

67 Athens Street  
Jefferson, Georgia 30549  
Phone: (706) 367-6309  
Fax: (706) 708-2505  
Email: [myarbrough@jacksoncountygov.com](mailto:myarbrough@jacksoncountygov.com)

Date: April 23, 2021

To: Fencing Companies

From: Myrna Yarbrough, Purchasing Manager

**RE: Addendum 2 to Jackson County ITB 210007, Furnish and Install Fence, Gum Springs Park, Jackson County**

1. Addendum 2 is hereby issued to answer questions, per attached.
2. All other terms and conditions in ITB 210007 remain unchanged.
3. Any inquiries concerning Addendum 2 should be made to Myrna Yarbrough, Purchasing Manager, (706) 367-6309 or via email at [myarbrough@jacksoncountygov.com](mailto:myarbrough@jacksoncountygov.com)
4. Jackson County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.
5. Bidders must acknowledge receipt of addenda, by either signing and attaching this copy, or by writing "Acknowledge Addenda #2" at bottom of the proposal.

Is all the fence 6' tall? The drawing does not show a retaining wall but the specs mention it with a 4 fence.

Is all the fence on the property line? Specs say property line fence to have barbed wire.

The fence is 6 ft. tall except for the backstops & batting cage section. The retaining wall and property line are not on this bid, they were included in the construction bid Magnum won. The football, baseball fields, and basketball courts, bidder can refer to the first addendum.

They do not make a 1.66" OD Sch 40 top rail with a swedged joint. Do you want to use an SPS20 rail that does?

The SPS20 is acceptable to use for the top rail with swedged joint.

Why are the line post 6' OC? Line post is changed to 10' OC

Please see attached new pricing sheet.

BID DOCUMENT

Price for batting cages only = \_\_\_\_\_

Price for remainder of work = \$ \_\_\_\_\_

Total price for all work = \$ \_\_\_\_\_

Completion time – \_\_\_\_\_

Signed: \_\_\_\_\_

Title: \_\_\_\_\_

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

City, State, Zip: \_\_\_\_\_

Phone number: \_\_\_\_\_

Email: \_\_\_\_\_

Contractor must acknowledge receipt of any addenda on either this form or by signing and returning a copy of the addenda with their bid package.