



ADDENDUM No. 1

**Project Number 22-42001-001
Invitation to Bid
Pea Ridge Road Resurfacing
Putnam County Board of Commissioners**

Date: April 8, 2022

1. QUESTIONS AND ANSWERS

Question 1: Can a typical section be provided to show the asphalt thickness?

Answer: The 12.5 MM asphalt thickness will be 1 ½" (165 lbs./SY) and the open graded crack relief will be placed at 90 lbs./SY.

Question 2: In the bid schedule, Item #020 25mm has a "0" (zero) for a bid quantity. Is that a typo and was this for some patch work prior to the OGI placement

Answer: The Bid Form was prepared before the final determination was made concerning the section to be utilized. There is no 25 MM included in the bid. Place a "0" (zero) in the total column for this line item.

END OF ADDENDUM