



City of Myrtle Beach
SOUTH CAROLINA

PURCHASING AND
MATERIALS MANAGEMENT

(843) 918-2170
FAX: (843) 918-2182

ADDENDUM 001

June 9, 2021

21-B0028


Transfer Station Pump Station

A Pre-Bid was held with the following in attendance:

Haren Construction	Scott Stewart
MB Kahn Construction	David Zabeco
Carolina Bridge, Inc.	Jerrell Roberson
MJL, Inc.	Averil McCoy
Xylem Dewatering Solutions	James Lehmann
Ruby Collins, Inc.	Andy Cook
Pro Pump & Controls	Reed Waterbury
Greenwall Construction	Denny Skiles
State Utility	Dustin Wagner
C.L. Benton	Edward Benton

Attached please find a new bid schedule that is to be used in lieu of the bid schedule in the documents, the civil plan set and a map showing manholes. Manholes #20-CB, 20-04 and 20-01 are not part of the relining, they are being abandoned.

Thank you,


Ruth Burleson Garigen
City of Myrtle Beach

UPGRADES TO TRANSFER SEWAGE PUMP STATION

DDC Engineers
From: Dylan Jordan, EIT
Project No. 21018E



ADDENDUM NO. 1 – June 8, 2021

This Addendum forms a part of the Bidding Documents and modifies the original Bidding Documents, dated May 2021, Bid Date Tuesday, June 29, 2021 at 2:00 pm.

Acknowledge receipt of this Addendum in the space provided on the PROPOSAL. Failure to do so may subject Bidder to disqualification.

The following items clarify, modify, change, delete from or add to the Bidding Documents. When any paragraph, subparagraph, or sub-subparagraph, thereof is modified or deleted by this Addendum, the unaltered provisions of that paragraph, subparagraph, or sub-subparagraph shall remain in effect. When any portion of a drawing is modified or deleted, the unaltered provisions of that drawing shall remain in effect.

1. An additional manhole has been added to the list of manholes to be lined. This additional manhole brings the total number of manholes to be lined to 13. The change has been shown with an additional item on the unit price form and the note on sheet C3.01 in the civil plan set has been revised to include this additional manhole.
2. Sheets C3.01 & C3.07 in the civil plan set show the conduit package needed for the proposed electric and communication conversion.
3. A conduit trench installation detail has been added to sheet C3.01 in the civil plan set.

END OF ADDENDUM #1

UPGRADES TO TRANSFER SEWAGE PUMP STATION
ENGINEER PROJECT NUMBER 21018E

DOCUMENT 004322 - UNIT PRICES FORM

1.1 BID INFORMATION

- A. Bidder: _____
- B. Project Name: Upgrades to Transfer Sewage Pump Station.
- C. Owner: The City of Myrtle Beach.
- D. Engineer: DDC Engineers.
- E. Engineer Project Number: 21018E

1.2 BID FORM SUPPLEMENT

- A. This form is required to be attached to the Bid Form.
- B. The project is a unit price contract.

1.3 UNIT PRICES

Item	Description	Engr's Est.	Bid Qty	Unit	Unit Price	Amount
UPGRADES TO TRANSFER SEWAGE PUMP STATION						
1.	Mobilization	1		LS	\$	\$
2.	Duplex Sewage Bypass Pumping System Complete, Pump, Force Main Connection, Piping, System Controls, Plus a Backup Pump, etc. (quiet pumps), if needed	1		LS	\$	\$
3.	Erosion Control	1		LS	\$	\$
4.	Demolition of Existing Pump Station and Removal of Existing 4" Pumps, wetwell and all wetwell components.	1		LS	\$	\$
5.	Remove Existing Pumps and Equipment, etc. to be Salvaged and Delivered to The City of Myrtle Beach	1		LS	\$	\$
6.	Furnish and Install New 6' Diameter Wetwell with Wetwell Lining System	1		LS	\$	\$
7.	Furnish and Install Duplex Flygt Submersible Pumps with Motors Complete	1		LS	\$	\$
8.	Furnish and Install a 4" DIP Discharge Pipe Complete (from Top of Pumps Through Valve Vault)	1		LS	\$	\$

UPGRADES TO TRANSFER SEWAGE PUMP STATION
ENGINEER PROJECT NUMBER 21018E

Item	Description	Engr's Est.	Bid Qty	Unit	Unit Price	Amount
9.	Valve Vault Complete Includes 4" Check Valves, 4" Plug Valves and 4" Dresser Couplings	1		LS	\$	\$
10.	Install Control Panel Complete	1		LS	\$	\$
11.	Install Electrical Service Complete	1		LS	\$	\$
12.	Pump Station Water Service Complete with 2" Post Hydrant	1		LS	\$	\$
13.	Restrain Existing 4" PVC Force Main	1		LS	\$	\$
14.	4" MJ Plug Valve with Box not including valve pit	3		EA	\$	\$
15.	4" MJ 45° Bend Restrained	7		EA	\$	\$
16.	4" x 4" MJ Tee 90° Bend Restrained	3		EA	\$	\$
17.	4" MJ 90° Bend Restrained	5		EA	\$	\$
18.	Proposed 8" SDR35 PVC Gravity Sewer Line	239		LF	\$	\$
19.	8" C-900 DR-18 PVC Manhole Drop Complete with Tee	1		EA	\$	\$
20.	8" C-900 DR-18 PVC Manhole Drop Complete with Wye	1		EA	\$	\$
21.	Rehab of Existing Manholes Lining System	7		EA	\$	\$
22.	4" Magnetic Meter with Vault Complete (Includes 4" Dresser Coupling Controller all Wiring to Control Panel and Power Service to Meter) Mount Mag Meter Output Controller in Control Panel	1		LS	\$	\$
23.	Furnish and Install Pump Station Back-up Float System	1		EA	\$	\$
24.	Furnish and Install a ¾" Schedule 80 PVC Airline and Air Bell System	1		EA	\$	\$
25.	4" #57 Stone with Filter Fabric on Pump Station Site	230		SY	\$	\$
26.	Emergency Pump Connect Complete (Included 4" x 6" Reducer, 6" Plug Valve bends, Piping and Slab)	1		LS	\$	\$
27.	Connection into Existing 4" PVC Force Main	1		EA	\$	\$
28.	6' High chain link Fence	95		LF	\$	\$

UPGRADES TO TRANSFER SEWAGE PUMP STATION
ENGINEER PROJECT NUMBER 21018E

Item	Description	Engr's Est.	Bid Qty	Unit	Unit Price	Amount
29.	Suction Pump Connection Complete	1		LS	\$	\$
30.	JIB Crane and Foundation	1		EA	\$	\$
31.	2" PVC Water Line	93		LF	\$	\$
32.	6"x 2" Tapping Sleeve & Valve w/Box	1		EA	\$	\$
33.	4" MJ 11.25° Bends Restrained	1		EA	\$	\$
34.	2" Double Check Detector Valve	1		EA	\$	\$
35.	Seeding	840		SY	\$	\$
36.	4" Engine Driven Pump CD130M Dri-Prime Pump Complete with Concrete Pad	1		LS	\$	\$
37.	4" Engine Pump Suction Piping from Pump to Wetwell	1		LS	\$	\$
38.	Flowable Fill	1		LS	\$	\$
39.	Remove existing 8" GS Line	70		LF	\$	\$
40.	4" Caps	2		EA	\$	\$
41.	Remove existing Generator & Fuel Tank	1		LS	\$	\$
42.	Reroute existing Sewer Service	1		LS	\$	\$
43.	Furnish and install 4' diameter Sewer Manholes with Rim & Cover (all Manholes to be coated)	5		EA	\$	\$
44.	18" Corrugated Plastic Pipe	260		LF	\$	\$
45.	Remove 18" CMP	252		LF	\$	\$
46.	Fine Grading	1		LS	\$	\$
47.	3x3 Catch Basin with Frame & Grate	3		EA	\$	\$
48.	E/C/T Conduit	1		LS	\$	\$
49.	Tree & Stump Removal	1		LS	\$	\$
50.	4" C900 DR-25 PVC Force Main	100		LF	\$	\$
51.	6" GABC Driveway	130		SY	\$	\$
52.	Miscellaneous Imported Fill	170		CY	\$	\$
53.	Doghouse Manhole to be Lined	1		EA	\$	\$
UPGRADES TO TRANSFER SEWAGE PUMP STATION TOTAL:						

UPGRADES TO TRANSFER SEWAGE PUMP STATION
ENGINEER PROJECT NUMBER 21018E

Total Amount: _____
In words Dollars

1.4 SUBMISSION OF BID SUPPLEMENT

- A. Respectfully submitted this ____ day of _____, 2021.
- B. Submitted By: _____ (Insert name of bidding firm or corporation).
- C. Authorized Signature: _____ (Handwritten signature).
- D. Signed By: _____ (Type or print name).
- E. Title: _____ (Owner/Partner/President/Vice President).

END OF DOCUMENT 004322

