



Board of County Commissioners • Escambia County, Florida

Paul R. Nobles/Purchasing Manager
Office of Purchasing

October 16, 2018

To: All Known Prospective Bidders

Addendum Number 2:

RE: Bauer Road Paved Shoulders Project
Specification Number: PD 17-18.044

All:

The following questions were provided. Response is highlighted in yellow:

1. The typical section shows a grade break at the roadway/shoulder connection and the details do not show this break. Is there or isn't there a slope break?
Contractor shall match existing slope for 1' wide saw cut strip in the existing roadway and construct the proposed shoulder in accordance with grade shown in the Typical Section.
2. The details show 1" of friction course, however, the bid tabulation and the typical section note shows 1 1/2". Is the friction course 1" or 1 1/2"?
Friction Course shall be 1 1/2" thick.
3. Note 1 indicates no feathering and note 2 indicates feathering. Which note is correct?
Delete the 2nd sentence from Note 1 and follow the feathering guidelines shown in Note 2.

This Addendum Number 2 is furnished to all known prospective Bidders. Please sign and return one copy of this Addendum, with original signature, with your proposal as an acknowledgement of you having received same. You may photo copy for your record.

Sincerely,


Buzz Roggenbuck

Sr. Purchasing Coordinator

Acknowledgement of Receipt of Addendum 2:

SIGNED: _____

COMPANY: _____