# Addendum 1

# City of Canton, Ohio

Purchasing Department 218 Cleveland Ave. SW, 4<sup>th</sup> floor Canton, Ohio 44702

| Playground Equipment Instal  | lation at Cornelia, Crenshaw, Garaux a | and Harmont Parks |
|------------------------------|--|-------------------|
| Item/Project                 |  |                   |
| Parks Department             |  |                   |
| <b>Responsible Departmen</b> | t                                      |                   |
| 2:00PM, 11/14/2023           |  |                   |
| <b>Proposals Due By</b>      |  |                   |
|                              | Proposal Submitted By:                 |                   |
| Company Name                 |  |                   |
| Street Address               |  |                   |
| City                         | State                                  | Zip               |
| Contact Person               | Phone No.                              | Email Address     |

#### Question 1:

All 4 play area sites prepared for us to come in and install our play equipment, no site work by us needed?

# Answer 1:

The awarded contractor will be responsible for the installation of the play curb and any site preparation.

## Question 2:

Crenshaw Park is very straight forward, all new, correct?

#### Answer:

That is correct, the entire play area is new. Project is approximately 8,000sf. 396 EWF CY. Borders needed are 4' sections around the play area.

# Question 3:

Cornelia Park – need square feet, number of borders, EWF CY?

#### **Answer:**

Cornelia Park-project is approximately 1,920 sf. Borders needed are 4' sections around the play area. 95 EWF CY. The attached drawing shows the new play area highlighted in yellow.

#### Question 4:

Garaux Park- need square feet, number of borders, EWF CY? Also, which items are to be new pieces of play equipment?

# **Answer:**

Garaux Park-project area is approximately 7,206 sf. Borders needed are 4' sections around the play area. 356 EWF CY

The attached drawing shows the existing play area highlighted in yellow.


## **Question 5:**

Harmont Park- need square feet, number of borders, EWF CY? Also, which items are to be new pieces of play equipment?

#### Answer:

Harmont Park-project area is approximately 3,808 sf. 229 EWF CY. Borders needed are 4' sections around the play area.

The attached drawing shows the existing play area highlighted in yellow.





150 PlayCore Drive SE Fort Payne, AL 35967 www.gametime.com

CANTON PARKS AND REC CORNELIA CANTON OH

Representative DWA RECREATION This play equipment is recommended or children ages

5-12


Minimum Area Required:
Scale: 1" = 5'-0"

This drawing can be scaled only when in an 18" x 24" format

IMPORTANT Soft resilient surfacing should be placed in the use zones of all equipment, as specified for each type of equipment, and at depths to meet the critical fall heights as specified by the U.S. consumer Product Safety Commission, ASTM standard F 1487 and Canadian Standard CANICSA-Z-814


TK Date 4.4.23

Drawing Name: TCANTON-CORNELIA-R



\*\*The area highlighted in yellow is existing equipment, as indicated.

The area above the yellow section is the new equipment area\*\*









This play equipment is recommended or children ages

Minimum Area Required:

Scale: 1" = 5'-0"

This drawing can be

iMPORTANT. Soft reasent surfacing should be placed in the use zones of a equipment, as specified for each type is equipment, and at depths to meet the critical fall heights as specified by the functional fall heights as specified by the functional fall heights are specified by the function of the functional fall heights are specified by the function of the function

Crewn By:
TK
Cuts
0,322/23
Drawing Name:
T CANTON-HARMONT