



THE CITY OF DAYTONA BEACH
OFFICE OF THE PURCHASING AGENT

Post Office Box 2451
Daytona Beach, Florida 32115-2451

Phone (386) 671-8080
Fax (386) 671-8085

ADDENDUM NO. 2

DATE: April 15, 2020

PROJECT: ITB 20361
**WESTSIDE REGIONAL WRF BATTERY REPLACEMENT UV-UPS
SYSTEM**

OPENING DATE: May 7, 2020

This addendum is hereby incorporated into the Bid Documents for the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~striketrough~~.

1. Questions and Answers:

Q1: Where is figure #1 showing 18" rise to doorway?

A1: The 18" rise is from the roadway to the doorway (Slight elevation)

Q2: Duracell DURHR12-540C/FR-A is a direct equivalent of Energys HX12-540, made by East Penn. Could that battery be considered also for the bid? (VR?)

A2: Yes

2. Attached are figure 1-"front entrance" and figure 2-"interior hallway" that were referenced but omitted in Addendum #1, Questions 4 and 8 respectively.

3. All other terms and conditions remain the same.

The Bidder shall acknowledge receipt of this addendum on the Bid Proposal Form.

The City of Daytona Beach
Kirk Zimmerman, CPPB
Buyer

Posted online at <https://www.codb/841.us>



Figure 1UV-UPS Front Entrance



Figure 2 UV-UPS Interior