



THE CITY OF DAYTONA BEACH
OFFICE OF THE PURCHASING AGENT

Post Office Box 2451
Daytona Beach, Florida 32115-2451

Phone (386) 671-8080
Fax (386) 671-8085

ADDENDUM NO. 3

DATE: April 14, 2020

PROJECT: ITB 20361
**WESTSIDE REGIONAL WRF BATTERY REPLACEMENT UV-UPS
SYSTEM**

OPENING DATE: May 7, 2020

This addendum is hereby incorporated into the Bid Documents for the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~striketrough~~.

1. Questions and Answers:

Q1: We are assuming that each battery cabinet has its own individual breaker. Can we replace multiple battery cabinets at once? VR

A1: Yes you can replace multiple battery cabinets at once but will have to have the system operational at the close of business each day.

Q2: Can the system stay on line or can we place it in maintenance bypass? VR

A2: While working on the system it can be placed in maintenance bypass but will have to be operational at the close of business each day.

A3: You reference a startup of the UPS does this mean a Vertiv Tech. is required on site at the time of the battery replacement and does the Vertiv tech have to start up the UPS? VR

A3: Yes

2. All other terms and conditions remain the same.

The Bidder shall acknowledge receipt of this addendum on the Bid Proposal Form.

The City of Daytona Beach
Kirk Zimmerman, CPPB
Buyer

Posted online at <https://www.codb/841.us>