

ADDENDUM NO. 02

**PROPOSED RENOVATIONS TO FOOTBALL/SOCCER FIELDS AT HOWARD HIGH SCHOOL, OOLTEWAH HIGH SCHOOL AND SODDY-DAISY HIGH SCHOOL
HAMILTON COUNTY, TN**

GENERAL

The following items covering changes in the bidding requirements shall apply to and become a part of the requirements thereof.

Receipt of this Addendum shall be acknowledged by inserting this number and date in the space provided on the Bid Form. Failure to do so may result in disqualification of the Bidder. This addendum consists of 02 pages, including drawings:

QUESTIONS

- 1Q. Is there a Geotechnical report available for each site?
1R. No.
- 2Q. Can alternative turf manufacturers be submitted for substituted?
2R. The documents do not have a specific turf manufacturer listed. The specifications do include specific criteria to be followed. Turf submittals made with the Bid/Proposal must meet the minimum specifications.
- 3Q. Can alternative turf systems be submitted for substitution?
3R. An alternative turf system may not be submitted for consideration in the Base Bid/Proposal. An alternative system can be submitted as either an Additive or Deductive Alternate listed in Optional Value Add/Delete Alternates portion of the Bid/Proposal Form with the corresponding dollar value to be considered.
- 4Q. Can Rakortan WBS BS Synthetic Track Surfacing be considered an Owner approved equal to the specified Basis of Design in Section 32 18 23.33 Running Track Surfacing for use at Ooltewah High School?
4R. Yes.

MISCELLANEOUS

No Items

SPECIFICATIONS

- ITEM 1 Section 32 18 14 – Infilled Synthetic Turf Systems
Replace Paragraph – 1.12D
Replace with: “Subsurface turf base and drain trench shall include, from the top: 2” of #89 stone and a depth of #57 stone to complete the cross-section. Cross-section varies by location due to storm drainage requirements. Install clean #57 stone surrounding the subsurface collector drainage pipe.”

DRAWINGS

- ITEM 1 HHS, OHS, SDHS – Sheet C7.01, Detail 1 – Replace “1/4” MINUS” with “#89”. Revised drawing will not be issued as part of this Addendum.
- ITEM 2 OHS – Sheet C7.02, Detail 7D – Add 1 ½” Asphalt Top Surface and 1 ½” Binder Course with 6” depth Compacted Aggregate Base for the field events added to OHS and for repairs to be made to the existing track. Revised drawing will not be issued as part of this Addendum.

Bidder Must Acknowledge Receipt of this Addendum on Bid/Proposal Form

March 26, 2024

Barge Design Solutions, Inc.
1110 Market Street, Suite 200
Chattanooga, TN 37202