



Oconee County Board of Commissioners

Addendum 3

DATE: April 22, 2022
TO: All Prospective Bidders/Offerors
FROM: Procurement Officer
RE: Addendum 3, RFP# 22-03-012 Fire Station No. 7 Roof Replacement

The following changes are to be incorporated into the solicitation documents dated **March 24, 2022**. All those receiving this addendum should modify their documents to show the below described changes.

1. Answers to questions received prior to the deadline of 5:00 pm on April 19, 2022.

All questions shall be directed to the Owner Contact, Jessica Ellis, Procurement Officer via email to ocbids@oconee.ga.us .

1. Answers to questions received prior to the deadline of 5:00 pm on April 19, 2022.

Q1: Is there a certain metal gauge thickness for the metal panels and trims?

A1: Panels and trim should be 24 gauge metal.

Q2: Are panels and trims to have a galvalume finish or a pre-finished Kynar painted finish?

A2: Panels and trim should have a Kynar painted finish.

Q3: Is there an R-Value requirement for the wall insulation?

A3: Wall insulation should have a minimum R-Value of R-13.

END OF ADDENDUM 3