



**Gilbert, Hawkins, Butts Street Sidewalk
RFB
ADDENDUM NO. I**

Project no. 1236

Friday, December 1, 2023

Answers to Questions Received

1. Will as-builts be required? If so, what are the requirements? **Yes, an As-Built Survey is required by a Registered Surveyor. A PDF Plan drawing and CAD file shall be provided to the Engineer and The City of Georgetown at the completion of the project before final closeout and acceptance of the project.**
2. Will permanent construction signs need to be installed? If so, how many and what locations? **The contractor shall follow the SCDOT traffic plan details provided in the Plans.**
3. Who is responsible for third party testing? **Third party testing will not be required. However, the contractor shall provide concrete delivery tickets with mix design and quantities for Pay Application purposes.**