

2018 Sidewalk Projects

Addendum #2

(posted August 30, 2018)

1. Is the Town looking to test the concrete being placed for compressive strength? I wasn't sure if the Town was going to provide a firm or if the Contractor would be responsible for this.

For the 2018 sidewalk project we did not budget for concrete testing since it is only for a sidewalk project we did not feel the need to test the compressive strength of the concrete. The sidewalk is a typical 3000 psi mix and the contractor should certify the quality of the concrete and reject/test the concrete if there is a question about the integrity of the mix.