



PURCHASING DIVISION

901 Broadway, N.E. • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 800.848.0298 (Tennessee Relay Center)
 Email: purchasing@kcdc.org
<http://www.kcdc.org/en/DoingBusiness.aspx>

Addendum

SOLICITATION NAME	HVAC Services at Nature’s Cove Q1417	ADDENDUM NUMBER	1	DATE	03-17-14
-------------------	--------------------------------------	-----------------	---	------	----------

KCDC is providing this addendum to answer questions that have been raised about this solicitation. To aid in readability, the questions are in black and the answers are in **bold** and the answers follow immediately below.

Q1	Does the speedi channel need to be run in the closet or just on the ceiling?
	Run Speedi Channel in the living space only. There is no need to put it in the closet area.
Q2	Some of the existing pads are cracked and/or chipped and would need to be removed and a new pad put in its place. Will this be allowed? Also the old pads are 24 x 24 and the new pads are 32 x 32. The overhang would be too great to support the new units. Can all pads be replaced and new pads leveled up
	Replace pads as needed without digging.