

Addendum 2

City of Canton, Ohio
Purchasing Department
218 Cleveland Ave. SW, 4th floor
Canton, Ohio 44702

Sugarcreek Water Treatment Plant Filter Backwash Dechlorination Facility

Item/Project

Water Department

Responsible Department

Tuesday, August 31, 2021 at 2:00 PM local time ****NEW BID OPENING DATE***

Bids Due On or Before

Bid Proposal Submitted By:

Company Name

Street Address

City

State

Zip

Contact Person

Phone No.

Email Address

Question:

I am looking for info in regards to Note 1 on sheet E-2 dated July 2021. Provide and install new 80 amp 3-pole thermal magnetic branch circuit breaker in existing Panel-E to feed new Dechlorination building. The breaker type, style, and AIC rating to match existing. Is there any info on this? In order to price this breaker the electrician would need pics or model numbers of existing Panel-E and breaker types.

Answer:

PROJECT PLANS:

1. **Sheet 18 of 19 (E-2).** ADD the following to Key Note 1 regarding the existing breaker type, style & AIC Rating “The existing panel is a Cutler Hammer/Westinghouse panel, 208/120V, three phase, 10KAIC. Cat # not legible.”

****Please note that since this addendum has been posted within 72 hours of the original bid opening date and time of August 24, 2021 at 2:00pm. Therefore, the bid opening date will be postponed by one week. The new bid opening date and time is Tuesday, August 31, 2021 at 2:00pm.**