

47th St. NW Storm Sewer Repair Project, GP 1241 (Phase 1) and
47th St. NW-Packard Ave. NW 78" Storm Sewer Rehab Project, GP 1198 (Phase 2)
The City of Canton Engineering Department

Addendum 3

City of Canton, Ohio
Purchasing Department
218 Cleveland Ave. SW, 4th floor
Canton, Ohio 44702

47th St. NW Storm Sewer Repair Project, GP 1241 (Phase 1) and
47th St. NW-Packard Ave. NW 78 Inch Storm Sewer Rehab Project, GP 1198 (Phase 2)

Item/Project

Engineering Department

Responsible Department

Monday, October 8, 2018 at 2:00 PM local time **Note New Bid Deadline**

Bids Due On or Before

Bid Proposal Submitted By:

Company Name

Street Address

City

State

Zip

Contact Person

Phone No.

Email Address

**47th St. NW Storm Sewer Repair Project, GP 1241 (Phase 1) and
47th St. NW-Packard Ave. NW 78" Storm Sewer Rehab Project, GP 1198 (Phase 2)
The City of Canton Engineering Department**

Request for Information 10:

Question:

Regarding paragraph "F" of Section 1.3 "Structural Requirements" of Appendix C (Technical Specifications Cured-In-Place Pipe for Mainline Renewal), should design conditions assume fully or partially deteriorated pipe?

Answer:

For liner design bidding purposes, the contractor shall assume the entire length of storm sewer to be fully deteriorated.

Invitation to Bid Change 2:

Request for Information 4 from Addendum 2 is being revoked and a one week extension to the bid deadline is being enforced. The new deadline for bid submissions is Monday, October 8, 2018 at 2:00pm local time.