

ADDENDUM #2
TO
SPECIFICATION AND CONTRACT DOCUMENTS

March 9, 2020

TO: ALL PLAN HOLDERS

FOR: ITB-010-2020

The purpose of addendum #2 is to answer a request for an approved equal to the GAF Acrylic Coating System

Contractor must acknowledge receipt of all addenda with submittal on the form provided herein.

1. Please accept Acrylink-G Acrylic Coating System and Carlisle High Solid Silicone as approved equals?
Answer: We will accept Acrylink-G Acrylic Coating system as an approved equal only if it offers the 20 year No Dollar Limit Material and labor leak free warranty. We will not accept the Carlisle High Solid Silicone Coating Roofing System.

No. 1 Dated _____

Signature: _____

No. 2 Dated _____

Signature: _____

THIS FORM MUST BE INCLUDED WITH PROPOSAL