

## Request for Qualifications No. 15-007 Addendum No. 2

### PEACH COUNTY GEORGIA

#### Sanitary Sewer Service Connections and Private Septic Tank Abandonment

---

**PURPOSE:**

Address Contractor Questions  
Clarifications and revisions

**ADDENDUM 2:**

**Any information or technical guidance presented in this addendum supersedes the RFQ and specifications.**

**The following responses address questions originating with various contractors:**

***1. How deep is the city sewer main and laterals?***

Plans can be reviewed at the Peach County Public Works Department. However, existing lateral stub-out elevations need to be determined in the field prior to sewer service installation. All service laterals have been installed to allow for a minimum 1% slope in accordance with the plumbing code. 2% is desirable if conditions permit.

***2. Why is there a 5' minimum burial depth for sewer pipe and does this mean we are expected to drop down to that depth immediately at the house connection?***

The 5' minimum burial depth shall be revised to 2' minimum. There may be some variance at the connection point at the house and a reasonable transition to 2' burial depth is expected.

***3. How do we deal with situations where the invert elevation of the sewer lateral is not deep enough to allow the proper 1/4 inch per foot slope you are requesting from city connection to house connection? Is a pump system allowed?***

All sewer connections have been designed and installed to be deep enough to allow for a minimum 1% slope from the house connection to the service connect located at the clean-out at the road right-of-way. Any cases where this is not the case should be reported to Peach County Public Works.

**Clarifications and Revisions:**

- The slope of the 4" service pipe shall be a minimum of 1%.
- Service piping shall be Schedule 40 PVC with glued fittings
- Native non-organic soils may be used as bedding and backfill. Care shall be taken to properly compact the bedding and backfilling material prior to and during pipe placement.
- Clean-out caps shall be threaded recessed brass caps (not PVC)