## **Tom Green County**



113 W. Beauregard San Angelo, Texas 76903 325-659-6500/Fax 325-659-5441

## RFB 21-012 Burma Rd. Repair

March 30, 2021

ADDENDUM NO 2: Notice to Bidders

- 1. Are densities required for subgrade prep.? TGC Response: Yes, densities are required.
- Which Item # in the TX DOT Specs. applied to the 8" thick (Fast Track) CRCP-(1)-20 Concrete? TGC Response: Please see specifications sheet below for "Continuously Reinforced Concrete Pavement CRCP (1)-20".
- What type rebar is required? TGC Response: Please see specifications sheet below for "Continuously Reinforced Concrete Pavement CRCP (1)-20".

Please include this signed addendum with your Response.

Sincerely,

1-2 9

Dustin Klein Procurement Supervisor Tom Green County

Company

Date

Signature

Please Print Name and Title



SECTION X - X



## GENERAL NOTES

1. DETAILS FOR PAVEMENT WIDTH, PAVEMENT THICKNESS AND THE CROWN CROSS-SLOPE SHALL BE SHOWN ELSEWHERE IN THE PLANS. PAVEMENTS WIDER THAN 100 FT. WITHOUT A FREE LONGITUDINAL JOINT ARE NOT COVERED BY THIS STANDARD.

2. USE COARSE AGGREGATES WITH A RATED COEFFICIENT OF THERMAL EXPANSION (COTE) OF NOT MORE THAN 5.5 X 10<sup>-6</sup> IN/IN/ °F AS LISTED IN THE CONCRETE RATED SOURCE QUALITY CATALOG (CRSQC).

3. ALL THE REINFORCING STEEL AND TIE BARS SHALL BE DEFORMED STEEL BARS CONFORMING TO ASTM A 615 (GRADE 60) OR ASTM A 996 (GRADE 60) OR ABOVE. STEEL BAR SIZES AND SPACINGS SHALL CONFORM TO TABLE NO.1 AND TABLE NO.2.

4. STEEL BAR PLACEMENT TOLERANCE SHALL BE +/- 1 IN. HORIZONTALLY AND +/- 0.5 IN. VERTICALLY. CALCULATED AVERAGE BAR SPACING (CONCRETE PLACEMENT WIDTH / NUMBER OF LONGITUDINAL BARS) SHALL CONFORM TO TABLE NO. 1

5. PAVEMENT WIDTHS OF MORE THAN 15 FT. SHALL HAVE A LONGITUDINAL JOINT (SECTION Z-Z OR SECTION Y-Y). THESE JOINTS SHALL BE LOCATED WITHIN 6 IN. OF THE LANE LINE UNLESS THE JOINT LOCATION IS SHOWN ELSEWHERE ON THE PLANS.

6. THE SAW CUT DEPTH FOR THE LONGITUDINAL CONTRACTION JOINT (SECTION Z-Z) SHALL BE ONE THIRD OF THE SLAB THICKNESS (T/3).

7. WHEN TYING CONCRETE GUTTER AT A LONGITUDINAL JOINT. THE TIE BAR LENGTH OR POSITION MAY BE ADJUSTED. PROVIDE 3 IN. OF CONCRETE COVER FROM THE BACK OF GUTTER TO THE END OF TIE BAR.

8. REPLACE MISSING OR DAMAGED TIE BARS WITHOUT ADDITIONAL COMPENSATION BY DRILLING MIN. 10 IN. DEEP AND GROUTING TIE BARS WITH TYPE III, CLASS C EPOXY. MEET THE PULL-OUT TEST REQUIREMENTS IN ITEM 361.

9. OMIT TIE BARS LOCATED WITHIN 18-IN. OF THE TRANSVERSE CONSTRUCTION JOINTS (SECTION X-X). USE HAND-OPERATED IMMERSION VIBRATORS TO CONSOLIDATE THE CONCRETE ADJACENT TO ALL FORMED JOINTS.

10. LONGITUDINAL REINFORCING STEEL SPLICES SHALL BE A MINIMUM OF 25 IN. STAGGER THE LAP LOCATIONS SO THAT NO MORE THAN 1/3 OF THE LONGITUDINAL STEEL IS SPLICED IN ANY GIVEN 12-FT. WIDTH AND 2-FT. LENGTH OF THE PAVEMENT.

11. THE DETAIL FOR THE JOINT SEALANT AND RESERVOIR IS SHOWN ON STANDARD SHEET "CONCRETE PAVING DETAILS, JOINT SEALS."

SHEET 1 OF 2

Design Division Texas Department of Transportation Standard CONTINUOUSLY REINFORCED CONCRETE PAVEMENT ONE LAYER STEEL BAR PLACEMENT T - 7 to 13 INCHES CRCP(1)-20 DN: TXDOT CK:KM DW: AN ск⊧VР FILE: crcp120.dgn CTxDOT: APRIL 2020 CONT SECT JOB HIGHWAY REVISIONS 0/10/2011 ADD GN #12 14/09/2013 REMOVE 6" AND 6.5" ADD CTE REQUIREMENTS 15/05/2017 CoTE AS RATED 4.3

DIST

COUNTY

SHEET NO.

Γ.,	Ī	т
√2		



10 FT

15 FT

DATE:

