



## QUESTIONS & ANSWERS

**THE PURCHASE AND INSTALLATION OF A  
4" IRRIGATION WELL AND 5HP PUMP AT THE  
RALPH SCHUMACHER SOCCER PARK  
(18507 US-98)  
Requisition No. PR-052324**

- 1) I am wondering if you know what the power source is going to be what voltage?  
**We're having a new 3 phase transformer installed and it will have up to 480 volts available.**
- 2) Do you know the distance power is going to have to be run?  
**We prefer it by within 30 feet but we won't be able to make a final determination until the new transformer is installed.**
- 3) Do we know the brand of the box that is going to be used for power?  
**We do not.**
- 4) And are you going to require back boards to be placed and the height and width of those that you are going to require.  
**No, backboards will not be required.**