

NOTICE OF SOLICITATION – INVITATION TO BID: Bulloch County Board of Commissioners Engineering Department and the Office of Capital Projects

DESCRIPTION OF PROJECT: The Bulloch County Board of Commissioners is accepting sealed bids from qualified contractors for this project: **Bulloch County Road Resurfacing. The project consists of approximately 10 miles of County Road resurfacing.**

Addendum #1

Question: Bidder Question: "What is the specified thickness for each road for Recycled Asphaltic Concrete 9.5 mm Superpave (GDOT Item Code 402-3103)? **Answer:** On all roads in the bid package, including the add alternates, the specified thickness for the 9.5 mm asphalt super pave is 1.25 inches. The quantities in tons were calculated using this thickness.

Signature

Date

Name of Company: _____

A copy of this addendum must be signed and returned in the submitted bid package. Failure to include the signed addendum will cause the submitted bid not to be considered for this project.