

To: Bidders for the Roundabout-Broad Street (SR14) At Country Club Road Project

From: Robi Higgins, LaGrange Purchasing Agent

Date: May 26, 2017

RE: Roundabout-Broad Street (SR14) At Country Club Road Project
Addendum Number 1 to the May 1, 2017 Bid Document

Below are clarifications/answers to questions/items discussed at the pre-bid meeting that occurred on Wednesday, May 17, 2017 and responses to questions received from contractors since the pre-bid meeting.

Questions/Answers Received Since May 17 Pre-Bid Meeting (As of 2:00 PM, Friday, May 26, 2017)

1. Will the roundabout circle be built under the GDOT Spec RA-2?

Yes

2. Is the City Working with the utility companies to prevent schedule interference?

As mentioned in the pre-bid meeting, the City of LaGrange is the electric provider and owner of the poles, and has been responsible for the relocation of poles thus far. There is one pole that cannot be relocated until construction begins due to the fact that the relocation spot is currently in a travel lane. LaGrange Utilities is on standby to relocate that one remaining pole when the opportunity arises. Charter Communication and AT&T are also on notice to reattach to the new poles.

3. It has been my experience utility providers take 30 to 60 days to relocate, will this too be included in the scheduling?

See previous question/answer. Also, the Contractor will not be penalized for delay(s) caused by overhead utility relocation(s).

4. Plans call for 4" raised concrete islands with Type 1 mountable curb. But all of the islands are landscaped. To clarify – would you like 4" curb backfilled with soil for the landscaping?

That is correct.

5. What is the landscaping item in the middle of the large island found on Country Club Road? Tree?

The landscape items in the center island are described in the legend on Sheet 7A (bottom left hand corner).

6. Will there be an area designated by the City as a lay down yard? Or should the Contractor try to secure an area in close proximity to the project?

The work site will be tight and the City does not own any property nearby. Materials and/or equipment can be stored in the right-of-way as long as sight distance is not affected. A possible lay down area may be the nearby LaGrange College parking lot. Perhaps the best contact to explore the use of that area would be:

*Mr. Martin Pirrman, Jr.
Executive Vice President & CFO
LaGrange College
(706) 880-8232
mpirrman@lagrange.edu*

7. Are the medians 4" raised concrete or are they landscaped? If they are raised concrete would you have them match the red cobble stone circle?

Except for the crosswalks and perimeter curb, they are landscaped (see Sheet C-7A).

8. Regarding the D-1, roundabout signs: They are 57 sf each and most likely go on the larger posts, maybe the I-beam posts. There are no details on the posts. Are they the same as the rest of the signs or is there a detail you would prefer we use.

See Detail sheet T3B (attached).