

	<h1>City of Wilson, NC.</h1> <h2>Addendum 1</h2>
<p><u>Please send inquiries and questions about this RFP to:</u> Ricky Wilson Purchasing Manager rvwilson@wilsonnc.org</p>	<p>RFP: 2022-19</p> <p>RFP Due Date: 05/31/2022 @ 2:00pm</p> <p>Contract Type: Water Chemicals</p>

Failure to acknowledge and return this addendum may subject items in the bid or entire bid to be not considered based on the below information. (If you have already submitted a bid proposal it may be considered with the exception of changes to Item 2. Please send addendum with updates below acknowledged, ****E-mail only to Ricky Wilson - rvwilson@wilsonnc.org for Addendum 1. Only Addendum 1 will be accepted by e-mail****). (E-mail with subject **Addendum 1-2022-19-WATER CHEMICALS**).

Vendor: _____

- **Update to Proposal for Bid 2022-19 Item 2:**

Item 2: polyphosphate/silicate. The specification needs to read.

(Minimum triphosphate: 10% as P₂O₅, minimum silicate: 65% as SiO₂, maximum orthophosphate: 0.05%; Shannon SNC-444 or approved equivalent. Provide specifications with bid). Price per Cwt. with changes noted: _____

- **Question 1: What are the chemical costs?**

The following are the current chemical cost being bid, except hydrated lime which is a new bid.

liquid hydrofluosilicic acid	\$20.55/cwt
polyphosphate/silicate	\$92.17/cwt
powdered activated carbon	\$1,730/ton
Liquid Sodium Hydroxide	\$432/ton
Liquid Ferric Sulfate	\$298/ton
liquid chlorine	\$1,350/ton

- **Question 2:** Please provide price currently paid after all extensions & adjustments. \$432.00 / dry ton
- **Question 3:** Please provide amount ordered or used in the past 12 months (5/1/21-4/30/22) or in CY 2021 if that is easier. Can accept this number in tons, dry tons, or pounds. 680 dry tons July 2021-May 15, 2022

- **Question 4:** Is a full truck load always ordered? A full truck load for us would be 45,000 lbs. Full truck loads not to exceed 45,000lbs
- **Question 5:** I would just like to confirm that the bid opening for the above will be open to the public? Yes the bid opening is open to the public; your rep is welcome to attend
- **Question 6:** Item 4 on the attached is for Bagged Hydrated Lime. It was our understanding the city no longer used any lime products. Would you please verify or inform me otherwise? From our Water Treatment plant manager: With the increasing costs of Sodium Hydroxide, we wanted to have the option to go back to using some Lime if we need to. Short answer, We are looking at restarting the lime feeder system this year.