



ADDENDUM NO. 1

Date: May 3rd, 2024

To: All Interested Parties

From: Alessia Bencomo, Procurement Specialist
Village of Palmetto Bay
9705 E. Hibiscus Street
Palmetto Bay, Florida 33157

Re: Invitation to Bid No. 2024-11-014
Paving and Drainage Improvements Project

This Addendum forms part of the Invitation to Bid (ITB) Package advertised on April 16th, 2024, and with a bid opening date of May 7th, 2024, with any amendments and/or additions noted below.

Question No. 1: Can the experience/reference be from our subcontractor?

Response: *Experience is preferably from the Prime Contractor; however, the Proposer may submit the experience from their subcontractor.*

Question No. 2: Could you please provide us with the budget/estimate for the subject project?

Response: *The cost estimate for this project is Three Hundred Fifteen Thousand Four Hundred Sixty-Five Dollars and Zero Cents (\$315,465.00).*

Question No. 3: What is the contract term for this project?

Response: *The contract term for this project is five (5) months.*

Question No. 4: Does the Proposer need to provide references even if the Proposer already does work for the Village of Palmetto Bay?

Response: *Yes, the solicitation mentions that each proposal must be accompanied by a list of at least three (3) references, which shall include all the information requested in the reference form. The Village should not be listed as one of the references provided.*

Question No. 5: Exhibit E calls out to remove the existing drainage wells (3 EA). Are these drainage wells? If so, what part of the well is to be removed? Does the casing need to be plugged?

Response: *These are old shallow/small diameter wells (with or without casing). Portion of well in conflict with proposed drainage structure at same location would need to be partially removed to allow for installation of new drainage structure. Casing would not need to be plugged.*

Question No. 6: In the bid form, Bid Item# 425-2 has an Estimated Quantity of 0 EA. Please confirm the correct quantity for this item.

Response: *Correct, quantity for 425-2 Manholes (Type J-7T) is 0 EA. Manholes proposed for this project should be 425-3 Manholes (Type P-7T).*

Question No. 7: What are the proposed Catch Basins & Manholes for this project? The dimensions are important to determine an accurate proposal.

Response: Drainage Structures are all P-Boxes, as per FDOT Standard Plans 425-010 (attached). For height of structure, price per the following:

Structures connected to French Drains 72" Height

Structures Non-Connected to French Drains 60" Height

Thank you,



Alessia Bencomo
Procurement Specialist

ACKNOWLEDGEMENT OF ADDENDUM SOLICITATION



Amendment/Modification No: 1

Amendment of RFP No: 2024-11-014

Title: Paving and Drainage Improvements Project

Name of Company _____

Date Addendum Received _____

Total Pages of Addendum including Acknowledgement 3

Print Name _____

Signature _____

All other terms and conditions stipulated in the original Village of Palmetto Bay Invitation to Bid shall remain in force. All addenda created will be incorporated into the final contract and must be acknowledged in all bids. This acknowledgement form must be included in the response and failure to sign and submit this form may result in rejection of your bid.