

OFFICE OF THE SULLIVAN COUNTY PURCHASING AGENT
3411 HIGHWAY 126 – SUITE 201
BLOUNTVILLE, TN 37617-0569

KRISTINIA DAVIS
PURCHASING AGENT

PHONE 423/323-6400

FAX 423/323-7249

Kris.davis@sullivancountytn.gov

ADDENDUM-1

TO

RFP E00116(KD) HVAC DUCTWORK AT CENTRAL HIGH
SCHOOL

1. The decorative block wall will be demoed and replaced by the Sullivan County School Maintenance Department around finished duct work.
2. Sullivan County School Maintenance Department will fill in around the interior wall where the existing duct comes through.
3. The only wall penetration to be cut out by contractor will be the return duct.
4. Main duct trunk line shall be rectangular, branch duct may be round.
5. Contractor to submit a shop drawing of proposed duct layout with bid submittal.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM TO EMAIL ADDRESS:
kris.davis@sullivancountytn.gov