



St. Johns River

Water Management District

Michael A. Register, P.E., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940 • www.sjrwmd.com

DATE: November 4, 2021

TO: Prospective Respondents

FROM: Amy Lucey, Procurement Specialist

SUBJECT: Addendum #2 to Invitation For Bid, #37379, Fabricate/Manufacture New Walkway Platforms

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your proposal documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

- Q1. After reviewing the job specifications and drawings, on sheet S4, detail 5 is showing 1 ½" dia. SCH.40 Aluminum elbows being used for the corners of the handrails. With a CNC automated handrail bender, we are able to eliminate the time-consuming cost of welding each individual elbow in place. Would you allow us to fabricate the handrails as one continuous piece of aluminum pipe eliminating weld joints and ultimately providing a stronger handrail system for the access walkways?
- A1: Yes – fabricating the handrails as one continuous piece of aluminum pipe which eliminates the weld is acceptable.

NOTE: The Proposal Due Date **remains** 2:00 p.m., **Thursday, November 18, 2021.**

Please acknowledge receipt of this Addendum on the Bid FORM provided in the proposal package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.