

# Addendum 1

**City of Canton, Ohio**  
Purchasing Department  
218 Cleveland Ave. SW, 4<sup>th</sup> floor  
Canton, Ohio 44702

GP1313 Timken Pl./Clark Ave. Connector Project

---

**Item/Project**

Engineering Department

---

**Responsible Department**

October 29, 2021

---

**Bids Due On or Before**

## **Bid Proposal Submitted By:**

---

**Company Name**

---

**Street Address**

---

**City**

**State**

**Zip**

---

**Contact Person**

**Phone No.**

**Email Address**

**GP1313 Timken Pl./Clark Ave. Connector Project  
Engineering Department**

**Question:**

On the bid form the curb is stated as Type 2-A curb with a quantity of 1300 LF. In the typical section located on sheet 3/16 on the plans, the curb is stated as Type 6 Curb.

Please clarify which curb is to be installed for this project.

**Answer:**

Plan Reference #34 Item 609 Description should read:

**“CURB, TYPE 6”**

It is the intent that the contractor shall build an ODOT Type 6 Curb.