

ADDENDUM NO. II

BID NUMBER: 305632

BID TITLE: Motorola MOSCAD Service & Support

DEPARTMENT: Waste Resources Division

DATE OF ADDENDUM: September 16, 2019

ORIGINAL BID DUE DATE: September 17, 2019

ORIGINAL BID DUE TIME: 2:00 p.m., e.s.t.

REVISED BID DUE DATE: September 18, 2019

REVISED BID DUE TIME: 2:00p.m., e.s.t.

REASON: ANSWERS TO QUESTIONS

Q. One centralized Wonderware system or multiple?

A. One Centralized System.

Q. InTouch or System Platform? Version?

A. InTouch is being phased out by the owner, however this contract requires knowledge of that system for continuity of operations.

Q. Does customer also have a Wonderware Historian?

A. This question does not pertain to this bid solicitation.

Q. MOSCAD Field Interface Unit or Gateway?

A. Gateway.

Q. Does customer have copies of all MOSCAD applications?

A. Yes.

Q. Which Motorola 800MHz radios? Maxtrac, MCS2000, MTS2000? Which model repeater? Maxtrac.

A. The model of repeater does not pertain to this bid solicitation.

Q. Do all sites communicate directly through repeater or are there any store-and-forward sites?

A. This question does not pertain to this bid solicitation.

Q. SCADAAlarm or Win911? Version?

A. Neither are being used at this time.

Q. Plans to migrate radios or to ACE?

A. This question does not pertain to this bid solicitation.

Q. Plans to upgrade Wonderware?

A. This question does not pertain to this bid solicitation.

Q. Repair: Board level or module/equipment swapout then send to GDS depot for repair?

A. The repair can be swap-out and sent for repair.

Q. What stock of spare parts does customer have?

A. A substantial stockpile of spare parts is maintained.

Q. Can they provide a general configuration of each RTU type in their system? ie what I/O modules per RTU type?

A. A detailed RTU configuration and I/O list per site is available and will be provided upon contract award.

Q. MOSCAD 420, 400, 300, or 200 CPUs?

A. MOSCAD 300.

Q. Which Toolbox version does the customer use and that the RTUs were programmed in?

A. This question does not pertain to this bid solicitation.

Q. Does MOSCAD read PLC via MODBUS? Or does PLC read MOSCAD and transmit data via cellular system?

A. This question does not pertain to this bid solicitation.

Q. Which version of software are PLCs programmed in?

A. This question does not pertain to this bid solicitation.

Q. PLC configurations and how they interoperate with MOSCAD?

A. This question does not pertain to this bid solicitation.

Q. Will PM services be performed for all MOSCAD RTUs?

A. Check radio and replace batteries, etc.... PM services are conducted yearly by the owner.

Q. Any known preexisting system issues?

A. No.

Q. Does Wonderware communicate directly with PLCs as well as with MOSCAD RTUs?

A. This question does not pertain to this bid solicitation.

Q. Can bid response be submitted electronically?

A. No. Please refer to instructions in bid solicitation.

Q. Can you provide a comprehensive inventory of the number and types of MOSCAD RTUs, i.e., Moscad, Moscad-L, Moscad-M, etc.?

A. An inventory will be provided upon contract award.

Q. What are the specs of the PLC cellular system?

A. This question does not pertain to this bid solicitation.

Q. When was the system originally installed?

A. The system has been installed and updated at various times.

Q. Do you need any repair services as part of this bid?

A. This question does not pertain to this bid solicitation.

(SIGNED): _____ (DATE): _____

(COMPANY): _____

Please sign one (1) copy of this page and return it with your quote, or separately and clearly labelled if your proposal has already been submitted, to the Purchasing Department (email: aberkowitz@chattanooga.gov; or fax to 423-643-7244 Attn: A Berkowitz; or mail to Purchasing Dept., Attn: A Berkowitz, 101 E. 11th Street, Suite G-13, Chattanooga, TN 37402.)

Retain a copy for your file.